IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

4100 37

PERMIT# 130384 PIN# ~~4625-87-3567.1369~~ 4625-72-5358 DATE August 18, 05

OWNER OR CONTRACTOR The Point on Norman LLC / Lande Haven PHONE: Business 363-6390 Home 375-5999

ADDRESS 2214 Brawley Sch Rd. Mooresville N.C. 28117

LOCATION Brawley Sch Rd on left just before jct w/ Jacob Road #20603

SUBDIVISION The Point BLOCK / SECTION 13 LOT 1369 LOT AREA .778Ac SITE CLASS PS DESIGN FLOW 460gpd L.T.A.R. .03

Septic Tank: 1000 Gallons; STB 4441 Date 8-4-06 ☒ New System ☐ Repair System Type: I, II, III, ☒ IV, V, VI

Pump Tank: 1000 Gallons; PT 27 Date 7-10-06 System Description: LP PPBPS

Pump Make Goulds Model LWE0312M Serial No. Repair System Description: LP PPBPS

Nitrification Field: No Fields 1 Square Feet 540/810 Linear Feet 270 Maintenance Agreement Required: ☒ Yes ☐ No

No Lines 3@90'(CF) Trench Width 24"min36" Max Trench Bottom Depth 36" Gravel Depth N/A

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms

☐ Business No. Employees

☐ Other

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments:/Conditions: ~~24~~ 36" max 96c

Initial site evaluation and layout performed by Paul Pennington and Kathleen Haven of S+ME

INITIAL SITE SKETCH

Checked - tanks & lines 9/22/06

See plan by S+ME

Comments/Conditions: 4/11/06 Reviewed Building plans & Site plan: House is 15Ft deeper than original House Foot print therefore it needs to be closer to road/ Front property line. (65Ft to front PL

AS BUILT SKETCH No Further bdrm)

Installed as drawn

3/16" hole, set 24 ft of head

Permit can be ~~suspended~~ or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 8-29-06 Installed by: Bob Mayberry RS

Improvement Permit by: _____ date 8-18-06 Operation Permit by: Maria H Dolson date 10/24/06

Authorization to Construct by: Maria H Dolson RS date 4/11/06 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK