IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 130344 PIN# ~~4625 62 3567.1380~~ 4625729903 DATE August 17, 05

OWNER OR CONTRACTOR The Point Norman, LLC (KINGSWOOD) PHONE: Business _____ Home _____

ADDRESS 2214 Brawley School Rd, Mooresville, N.C. 28117

LOCATION Brawley School Rd TL Chesterwood on left

SUBDIVISION The Point BLOCK / SECTION 13 LOT 380 LOT AREA .877 Ac SITE CLASS. PS DESIGN FLOW 480 gpd L.T.A.R. .63

Septic Tank: ~~1000~~ 1500 Gallons; STB 338 Date 10/20/06

Pump Tank: _____ Gallons; PT _____ Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair System Type: I (II) III, IV, V, VI

System Description: Gravity 25% Reduction (accepted)

Repair System Description: LPPPBPS

Maintenance Agreement Required: ☐ Yes ☒ No initially

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Bathrooms ____ No. Employees ____

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments:/Conditions:

Initial site evaluation and layout performed by Paul Lemmon and Kathleen Haven of S&ME

Comments:/Conditions: EZ FLOW IN STALLED

INITIAL SITE SKETCH

See plan by S&ME

AS BUILT SKETCH

5-6 5-5

6-9 6-10

7-8 7-9

9- 9-1

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plan valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 8-25-05 Installed by: HALLMAN CONST.

Improvement Permit by: _____ date 8-17-05 Operation Permit by: Wesley Sparks R.S. date 12/6/06

Authorization to Construct by: _____ date 2/28/06 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK