**IREDELL COUNTY HEALTH DEPARTMENT - *ENVIRONMENTAL HEALTH*** ☐ STATESVILLE OFFICE 704-878-5305 ☐ ESVILLE OFFICE 704-664-5281

**IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION**

3100

PERMIT # 174370 PIN # 4625-73-7800 DATE 8-29-12

OWNER JOSEPH DEMPSY APPLICANT: MIKE ATHANAS PHONE: Home/Cell # 704-576-3887 Business #

SITE ADDRESS 1998 BRAWLEY SCHOOL RD OWNER / APPLICANT ADDRESS SAME

SITE DIRECTIONS 1998 BSR

SUBDIVISION THE POINT BLOCK / SECTION 6 LOT # 638 LOT AREA 1.296 AC DESIGN FLOW 600 L.T.A.R. .3

Septic Tank 1500 Gallons: STB 338 Date 3-17-13 ☒ New System ☐ Repair ☐ Expansion System Type I II III IV V VI

Pump Tank 1500 Gallons: P T 477 Date 3-15-13 System Description: PM 25% REDUCTION

Pump Make Model Serial # Repair System Description: LP-PANEL

No. Nitrification Fields: 1 No. Lines 5 Linear Feet 500' Maintenance Agreement Required ☐ YES ☐ NO

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth — ☐ GRAVITY ☒ PRESSURE

☐ Residence No. Bedrooms 5 ☐ Business No. Persons ☐ Other No. Employees ☐ Slab ☐ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☐ Community

Comments / Conditions

4/18/13 Checked tanks
4/24/13 Checked lines (see As Built)
Some rock in header ditch

INITIAL SITE SKETCH

SEE APPROVED PLAN
BY
MIKE ATHANAS
BA

AS BUILT SKETCH

CHECKED
ELEC ALARM
SET BY PH
5-20-13

See revised Drawing Attached For As Built

*Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.*

☐ ***IMPROVEMENT PERMIT*** *with plat valid without expiration.* ☒ ***IMPROVEMENT PERMIT*** *with plat valid without expiration. site plan valid 60 mo.* ☒ ***AUTHORIZATION TO CONSTRUCT*** valid for period equal to IMPROVEMENT PERMIT–not to exceed 60 mo.

Owner / Applicant Signature: Date 9/4/12 Installed by: Steve Jordan

IMPROVEMENT PERMIT by: REHS Date 8-29-12 OPERATION PERMIT by: REHS Date 5-20-13

AUTHORIZATION TO CONSTRUCT by: REHS Date 9-4-12 Existing System Inspected by: REHS Date

***YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION***

White Copy – Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant