IREDELL COUNTY HEALTH DEPARTMENT - ENVIRONMENTAL HEALTH ☐ STATESVILLE OFFICE 704-878-5305 ☒ MOORESVILLE OFFICE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

4120 Paid $655

PERMIT # 14222 PIN # 4625 74 5153 DATE June 14, 2012

OWNER Christian & Lisa Kiral APPLICANT: Stonebridge Lux Homes PHONE: Home/Cell # Business # 400-1235

SITE ADDRESS 115 Stonewall Beach Ln. Mooresville OWNER / APPLICANT ADDRESS P.O. Box 1167 Winston-Salem NC.

SITE DIRECTIONS Brawley School Rd. TR Stonewall Beach on left

SUBDIVISION The Point BLOCK / SECTION 6 LOT # 635 LOT AREA .81 Ac. DESIGN FLOW 480 gpd L.T.A.R. .3 gpd/ft²

Septic Tank 1500 Gallons: STB 338 Date 3-9-13 ☒ New System ☐ Repair ☐ Expansion System Type I II III (IV) V VI

Pump Tank 1500 Gallons: PT 27 Date 3-9-13 System Description: LP PPBPS

Pump Make ORENCO Model 500512 Serial # 9285-5010 Repair System Description: LP PPBPS

No. Nitrification Fields: 1 No. Lines 6 Linear Feet 280 Maintenance Agreement Required ☒ YES ☐ NO

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA ☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 4 ☐ Business No. Persons ☐ Other No. Employees ☒ Slab Garage ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions

-Fill to be removed in system area
-min. 15' from pool to system repair or tanks
OK to use 1000gal PT

6/19/12 Reviewed Floor plans, in Compliance with original permit.
4/10/13 Checked tanks

INITIAL SITE SKETCH

See Plan from S&ME.
Approved by ICHD

AS BUILT SKETCH

INSTALLED SUBSTANTIALLY AS SHOWN
3' PH SET
CHECKED ELEC/ALARM 5-15-13

The proposed / existing Pool addition does not appear to impact the existing septic system.
**NOTE:

Judy Melvill R.S.
Date: 5-21-13
ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ IMPROVEMENT PERMIT with plat valid without expiration. ☒ IMPROVEMENT PERMIT with plat valid without expiration. site plan valid 60 mo. ☐ AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Owner / Applicant Signature: X Date

IMPROVEMENT PERMIT by: Judy Melvill REHS Date 6-14-12

AUTHORIZATION TO CONSTRUCT by: REHS Date 6-19-12

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

Installed by: Steve Jordon

OPERATION PERMIT by: REHS Date 5-15-13

Existing System Inspected by: REHS Date

White Copy -- Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant