DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: 401 Point pk 4 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-19	BSCL WSBK	FRI SS SP					P5 1.3
		19-48	RC/C WSBK	FRI SS SP					
2		0-15	BSL WSBK	FRI SS SP					P5 3
		15+	RL SBK/MASS	FRI SS SP					
3		0-8	BSL GR	FRI SS SP					(4)
		8-23	YRL MFSBK	FRI SS SP					
		23-49	RYSCL SBK	Inc of CL FRI SS SP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

DRIVE
237'
34'
63'
775
780
785
770
765
760
755
130'
122'
119'
124'
R=42'
R=50'
Delta=343°24'41.92"
PC 10+41.92
PT 11+00
403
37,791 sq.ft.
CRAWL
BASEMENT
402
40,322 sq.ft.
CRAWL
BASEMENT
401
40,984 sq.ft.
CRAWL
BASEMENT
400
37,768 sq.ft.
CRAWL
BASEMENT
CENTERLINE
R=350.14
L=244.41
Tan=127.24
Delta=39°19'13"
335'
334'
313'
S01°35'49"E
61.43'
125'
122'
RC
EOP
R/W
B-B
22'
18'
4+00
10+86.55
12+63.96
14+47
15+25.96
17+00