DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET___OF___
PROPERTY I.D.#:___
PROPERTY RECORDED:___
COUNTY:___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: CRI OWNER:__AGENT:__ PHONE:___
ADDRESS:___ APPLICATION DATE:___ DATE EVALUATED: 5/24/85
PROPOSED FACILITY: 480 gpd SFR
PROPERTY SIZE:___
LOCATION OF SITE: Lot 17 Yacht Shores II
WATER SUPPLY: On-Site Well ✓ Comm. Well___ Public___ Other___ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-11	gr - scl	fr					.3
		11-30	sbk - c	fi					
		30-48	msbk - cl	mfi					
2		0-8	gr scl	fr ss/sp					.3
		8-31	ssbk - c	fi					
		31-47	msbk - cl	mfi					
3									
4									
5									

AVAILABLE SPACE (.1945) PS SITE CLASSIFICATION (.1968): PS SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: [illegible] OTHER(S) PRESENT:___
COMMENTS:___