HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY I.D.#: 2C52A3
PROPERTY RECORDED: YES
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: R&L MacLeod OWNER: ✓ AGENT: PHONE:
ADDRESS: 128 Lakeshore Rd. N. Denver, NC APPLICATION DATE: 10/26 DATE EVALUATED: 10/26/93
PROPOSED FACILITY: 3 bedroom SF Dwell.
PROPERTY SIZE: 153 x 147
LOCATION OF SITE: lot 3, Yacht Cove off SR 1101
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LS	0-3"	SAb / cL	1&1 / fr	—	—	PS	—	.05
		3-34"	SAb / C	1&1 / fi	—	—	PS	—	.35
		34-48"+	SAb / SiC	1&1 / fi	—	—	PS	—	.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945): PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: DW Johnson OTHER(S) PRESENT: Bob MacLeod
COMMENTS: