DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY I.D.#: _____

PROPERTY RECORDED: _____

COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: New Treads Homes OWNER: __ AGENT: __ PHONE: _____

ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____

_____ PROPOSED FACILITY: _____

LOCATION OF SITE: Lot 4, Yacht Cove PROPERTY SIZE: _____

WATER SUPPLY: On-Site Well X Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-24"	C SBK	1:1 / Ai	—	—	PS	—	.3-.4
		24-48	SICL wk SBK	1:1 / fri	—	—	PS	—	.25-.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945): U SITE CLASSIFICATION (.1948): U SITE LONG-TERM ACCEPTANCE RATE: .3

EVALUATED BY: [illegible] OTHER(S) PRESENT: _____

COMMENTS: Site can be reclassified PS under rule 1956 modified systems PBPS