HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 2C2A 5
PROPERTY RECORDED: YES
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MAX Spear
ADDRESS: 607 Andersen Ave
OWNER: AGENT: ✓ PHONE: 636-7854
APPLICATION DATE: 6/28/93 DATE EVALUATED: 6/30/93
PROPOSED FACILITY: 3 bedroom S.F. Dwelling
PROPERTY SIZE: ~21,000 ft²
LOCATION OF SITE: lot 5, Yacht Cove
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	55~2%	0-7"	gr. / scL	1:1 exfi/dry	NONE	NONE	PS	—	.4
		7-27"	sbk / c	1:1 fi clay	NONE	NONE	PS	—	.3-.4
		27"-48"	wk sbk sicl	1:1 fr	NONE	NONE	PS	—	.3
2									
3									
4									
5									

AILABLE SPACE (.1946) PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3gal/ft²/day
ALUATED BY: [illegible] IRS OTHER(S) PRESENT: MAX Spear
MMENTS: House site to be positioned 40' off rear of lot to accomodate gravity conventional system in front.