DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Hopkins & Hopkins Const. OWNER: AGENT: PHONE:
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: Dec 6, '93
PROPOSED FACILITY: 3 bedroom SF Dwelling
PROPERTY SIZE: ___
LOCATION OF SITE: Lot B, Yacht Cove off Kelly Rd
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LS	0-12"	SAb / cl	1o1 / fr	—	—	PS	—	.5
		12-36	SAb / c	1o1 / fi	—	—	PS	—	.4
		36-48+	wk SAb / SiCl	1o1 / fi	—	—	PS	—	.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945): ___ SITE CLASSIFICATION (.1948): ___ SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: ___ OTHER(S) PRESENT: ___
COMMENTS: Site can be reclassified PS per rule .1956 modified systems OK BPS.