DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH


SHEET____OF____
PROPERTY I.D.#:_____
PROPERTY RECORDED:_____
COUNTY:_____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: New Trend Homes OWNER:__AGENT: ✓ PHONE:_____
ADDRESS:_____ APPLICATION DATE:_____ DATE EVALUATED:_____
PROPOSED FACILITY: 3 bedroom SF Dwelling
PROPERTY SIZE:_____
LOCATION OF SITE: Lot 29, Jacket Cove
WATER SUPPLY: On-Site Well ✓ Comm. Well___Public___Other_____ EVAL. METHOD: Auger Boring ✓ Pit___Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1									
2									
3									
4									
5									

AVAILABLE SPACE (.1945)_____ SITE CLASSIFICATION (.1948): 5 per 1956 SITE LONG-TERM ACCEPTANCE RATE: 0.3
EVALUATED BY: DRJ Johnson OTHER(S) PRESENT: Andrea Lemon on original evaluation w/ Mike Tate
COMMENTS: This site was evaluated in the previous few months. A loading rate (LTAR) of .3 gal/sf/day was assigned to the area shown for drainfield installation on the SP. DRJ


wall
100'x3
100'x3
Jaclert Rd. Rw