DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

# SOIL/SITE EVALUATION
## *for* ON-SITE WASTEWATER SYSTEM

OWNER: Point 13 APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: 6/25
PROPOSED FACILITY: House PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: ___
LOCATION OF SITE: ___ PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
1379

| PROFILE # | .1940 LANDSCAPE POSITION/ SLOPE % | HORIZON DEPTH (IN.) | SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE | .1941 CONSISTENCE/ MINERALOGY | OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR | .1943 SOIL DEPTH | .1956 SAPRO CLASS | .1944 RESTR HORIZ | PROFILE CLASS & LTAR |
|---|---|---|---|---|---|---|---|---|---|
| 1 | Linear 8-10% | 0-11 | WK SBK SL | SS SP FR | Lt Br | | | | .3 |
| | | 11-36 | Mo SBK SCL | SS SP FR | Lt Red Br | | | | |
| | | 36-48 | Mo SBK CL | SS SP FR | Red; F sap | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| 2 | Linear 6-8% | 0-7 | Mo GR SL | SS SP FR | Br | | | | .3 |
| | | 7-12 | WK SBK SCL | SS SP FR | Red Br | | | | |
| | | 12-29 | Mo SBK C | SS SP FR | Red; F sap | | | | |
| | | 29-48 | WK SBK CL | SS SP FR | Red; C [illegible] CL SR | | | | |
| | | | | | | | | | |
| 3 | 15% + L | 0-8 | gr brn SL | fr SS SP | | | | | .3 |
| | | 8-56 | Wk m sbk up | fr SS SP | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| 4 | 10-15% L | 0-7 | gr brn SL | fr SS SP | | | | | .3 1/2 48" .257 48" |
| | | 7-48 | Mod sbk RCL | fr SS SP | | | | | |
| | | 48-51 | Wk sbk gy CL | fr SS SP | Few relic mottles Few brn & gy mottles | | | | |
| | | | | | | | | | |
| | | | | | | | | | |

| DESCRIPTION | INITIAL SYSTEM | REPAIR SYSTEM |
|---|---|---|
| Available Space (.1945) | | |
| System Type(s) | | |

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___