IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281 375

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 130338 PIN# 4625-82-3567-01375 4625824765 DATE August 10, 05

OWNER OR CONTRACTOR Point on Norman LLC / Dick West / Kings Wood Homes PHONE: Business 704 488 1960 Home

ADDRESS 2214 Brawley School Rd. Mooresville, N.C. 28117

LOCATION Brawley School Rd TL Chesterwood at end

SUBDIVISION The Point BLOCK / SECTION 13 LOT 1375 LOT AREA .885 Ac SITE CLASS PS DESIGN FLOW 480 gpd L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 444 Date 4/26/06
Pump Tank: ____ Gallons; PT ____ Date ____
Pump Make: ____ Model ____ Serial No. ____
Nitrification Field: No Fields 1 Square Feet 1260 Linear Feet 420
No Lines 6@70' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/K

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI
System Description: Gravity 25% Reduction
Repair System Description: LPPPBPS
Maintenance Agreement Required: ☐ Yes ☒ No initially

☒ House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Bathrooms ____
☐ Business No. Employees ____
☐ Other ____
☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments:/Conditions:
Limited site evaluation and layout performed by Paul Pennington and Kathleen Hiser with S&ME

Comments:/Conditions: EZ FLOW INSTALLED WITH SINGLE SIX HOLE DIST. BOX W/SPEED LEVELERS

INITIAL SITE SKETCH

SEE plan by S+ME

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with ~~plat~~ valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: ____ date 8-29-05 Installed by: Kevin Hellman

Improvement Permit by: ____ date 8-10-05 Operation Permit by: Wesley Sparks RS date 7/28/06

Authorization to Construct by: ____ date 12/20/05 Existing System Inspection by: ____ date ____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK