IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

$130 11:00

PERMIT# 11897E PIN# 4625-83-4957 .1345 4625-82-5149 DATE June 15, 04

OWNER OR CONTRACTOR Crescent Resources LLC / The Point on Norman / Tom Stevens Business Home

ADDRESS 2214 Brawley School Rd Mooresville, N.C. 28117

LOCATION Brawley Sch Rd - TL Yacht Rd. TL Milford Circle on left

SUBDIVISION The Point BLOCK / SECTION 13 LOT 1345 LOT AREA .93Ac + .515Ac SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. ~.25

149.44

Septic Tank: ~~1000+1500~~ Gallons; STB 12-23-05 Date 338

Pump Tank: 1000 Gallons; PT 12-12-05 Date 27

Pump Make Myers Model ME 50 Serial No.

Nitrification Field: No Fields Square Feet 1500 Linear Feet 500

No Lines 5 Trench Width 36" Max Trench Bottom Depth 36"

☑ New System ☐ Repair System Type: I II III IV-A V VI

System Description: pm 25% Reduction

Repair System Description: pm 25% Reduction

Maintenance Agreement Required: ☐ Yes ☑ No

Gravel Depth NA

☑ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms 4

☐ Business No. Employees

☐ Other

☐ Slab ☑ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☐ ~~Public~~ ☑ ~~Community~~

Comments:/Conditions:

PT

ST

50' Setback

ROW

2-1-06

Comments:/Conditions:

Renewed Building plans & Site plan essentially in Compliance with I.P.

Tanks & Lines Checked

1/26/06 10/4/05

1"=50'

INITIAL SITE SKETCH

House Site

90'

85'

20'

340.44'

292.80'

15'

ST

PT.

DRIVEWAY

To Site 1358-1345

RW Milford Circle

Not to Scale

AS BUILT SKETCH

Installed as Drawn

Used EZ Flow for Drainfield

4"SCH 80 pvc

SFE 1358-1345

REPAIR AREA

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 6-22-04

Improvement Permit by: date 6-15-04

Authorization to Construct by: RS date 9/2/05

Installed by: R & H RS

Operation Permit by: date 7/19/06

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK