IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

450.00 Pd. 10.00

PERMIT# 132047 PIN# 4625 86 0097.000 DATE 3/7/06

OWNER OR APPLICANT Kingswood Custom Homes PHONE: Business 704-309-4575 Home

ADDRESS 8033 Corp Center Dr. Charlotte NC 28217

LOCATION 1100 TR Calpis TL Jeremy Point TR Brick Kiln on (R) at Masthead Ct.

SUBDIVISION POINT BLOCK / SECTION 5 LOT 518 LOT AREA ~~.578~~ 1.85 SITE CLASS. PS DESIGN FLOW 600 L.T.A.R. .25

Septic Tank: 1500 Gallons: STB 338 Date 11-23-06
Pump Tank: 1000 Gallons: PT 27 Date 12-8-06
Pump Make: Goulds Model 6HP WE05 Serial #
Nitrification Field: No Fields 1 Square Feet 800/1200 Linear Feet 400
No Lines 5@80' Trench Width 2-3' Max Trench Bottom Depth 3' Gravel Depth No

[X] New System [ ] Repair [ ] Expansion System Type: I II III (IV) V VI
System Description: Pres Dosed 16" PABPS
Repair System Description: SAME
Maintenance Agreement Required: [X] Yes [ ] No

[X] House/Mod. Home [ ] Mobile Home [ ] Business [ ] Other
No. Bedrooms ~~3~~ 4 No. Persons 4 No. Employees

Water Supply: [ ] Individual [ ] Public [X] Community

[ ] Gravity [X] Pressure [ ] Slab [ ] Crawl Space [X] Basement w/plumbing [ ] Basement wo/plumbing

Comments/Conditions:
4
175
West Mead Ct.
III <-NU
INITIAL SITE SKETCH
Repair
81'
Fill 7.6'
Brick Kiln Way
Some Repair
40
N P D

Comments/Conditions:
4080
Checked tanks, lines & pressure 3/6/07
~~See~~ "As Built" Drawing
OK to switch back to 4 Bedroom House
AS BUILT SKETCH
30'
54'
54'
30'
15'
10'
6'
17'4"

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration [ ] Improvement Permit with site plan valid for sixty months [ ] Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: X [signature] date 4/25/06 Installed by: Kevin Hallman RS 7/3/07

Improvement Permit by: Wesley Sparks RS date 3/7/06 Operation Permit by: Marvin Dolan RS date

Authorization to Construct by: Wesley Sparks RS date 3/7/06 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK