IREDELL COUNTY HEALTH DEPARTMENT

Lynette Korte $125

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 081174 (124739) PIN# 4625446084 (pt) 4625865473 DATE June 22, '99

OWNER OR CONTRACTOR Crescent Resources, Inc. // The Point ON Norman Pt PHONE: Business 660-1185 Home

ADDRESS 2214 Brawley Sch Rd. Mooresville

LOCATION Brawley Sch Rd. TR Polpis Road on Right

SUBDIVISION The Point BLOCK / SECTION 5 LOT 510 LOT AREA 39,574 SITE CLASS PS DESIGN FLOW 440gpd L.T.A.R. .03

Septic Tank: 1000+150 Gallons; STB 338 Date 9/4/05

Pump Tank: 1000 Gallons; PT 283 Date 8/30/05

Pump Make: Gomes Model 4SE05.5 Serial No 6555440

Nitrification Field: No. Fields 1 Square Feet 1200 Linear Feet 400

No Lines 5@80' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA

☑ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: PM- Innovative -25% Reduction

Repair System Description: LP Panel Block

Maintenance Agreement Required: ☐ Yes ☑ No

☑ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Bathrooms 4 No. Employees

☑ Slab ☑ Crawl Space ☑ Basement w/plumbing ☐ Basement wo/plumbing


Water Supply: ☐ Individual ☑ Public ☐ Community

Comments:/Conditions: *ONE inspection port per lateral
Remove old terraces.

Comments:/Conditions: (partial)
Installed Quick 4 5 x 80's as per initial site sketch. 27' from foundation drain to drainfield

1"=50'

INITIAL SITE SKETCH



Location of the proposed Inground Spa addition does not appear to impact the existing on-site septic system.**NOTE:

Marie Johnson REHS

Date: 3/4/13

ICHD-Environmental Health Division

Location of the proposed Patio & fire pit addition does not appear to impact the existing on-site septic system.**NOTE: Must stay at least 5ft from Septic System.

Marie Johnson REHS

Date: 5/8/13

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date

Improvement Permit by: date 6-22-99

Authorization to Construct by: date 4/22/05

Installed by: Osbourn & Sons

Operation Permit by: Wesley Sparks R.S. date 2/9/06

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK