11514

IREDELL COUNTY HEALTH DEPARTMENT 4625 902211

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR David Murphy DATE 8/29/91 PERMIT NO. 2C-2A-14

PHONE: Business _____ Home _____

LOCATION YACHT RD.

SUBDIVISION NAME YACHT COVE S. R. No. _____

LOT NO. 14 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2.5

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20,000 FT²

Character & Porosity of Soil P clay - firm - SS


Percolation Rate .3

Topography 1-3%

Depth to Water Table >36"

Rock or other impervious formations None observed

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System YACHT RD.

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. _____ Linear Ft. 212 ✗

Depth of Stone in Lines _____

Water Supply: Individual (✓)

Public ( )

✗ PPBPS 16" Panel-

Installed by F J Erwin

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: Trenches shallow, Obst with speed levlers,

CERTIFICATE OF COMPLETION BY Wesley Sparks R.S. DATE 8/29/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold