IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 119919 PIN # 4625 91 69602 DATE August 3, 2010

OWNER or APPLICANT Courtland Builders PHONE: Business 704-363-1622 Home:

OWNER or APPLICANT ADDRESS P.O. Box 3190 Mooresville NC 28117

LOCATION / DIRECTIONS Brawley Sch. Rd. TL Yacht Rd. TL Milford on Right 198 Milford Cr

SUBDIVISION The Point BLOCK / SECTION 13 LOT # 13&4 LOT AREA 1.09 Ac. DESIGN FLOW 480gpd L.T.A.R. .225 gpd/ft²

Septic Tank 1000 Gallons: STB 444 Date 12-29-1

Pump Tank Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines Linear Feet 550

Trench Width 36" Max. Trench Bottom Depth 18" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type I II III IV V VI

System Description: 25% Reduction Gravity Chamber

Repair System Description: LPPPBPS

Maintenance Agreement Required ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4

☐ Business No. Persons 8

☐ Other No. Employees

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions * per plan specs
Install chamber type system with approved serial distribution

Comments / Conditions

INITIAL SITE SKETCH

See Plan from Michael Athanas & Assoc.
Approved by ICHD

Max. 18" Trench Bottom Depth
Install on Contour of the ground

AS BUILT SKETCH

Installed ADS 36"
essentially as Drawn

The proposed / existing Pool addition does not appear to impact the existing septic system.
**NOTE: See approved site plan
Judy Melville REHS
Date: 2-28-11
ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Date 8-5-10

Improvement Permit by: Judy Melville Date 8-4-10

Authorzation to Construct by: Judy Melville Date 8-5-10

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: R & H Odom RS

Operation Permit by: Date: 2/9/11

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant