IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

4:00

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 164618 PIN # 4625 97 9055 DATE December 30, 2010

OWNER or APPLICANT Stonebridge Homes / Thomas & Chris Robillard PHONE: Business 704-658-1404 Home: 704-660-5780 cell

OWNER or APPLICANT ADDRESS PO Box 4297, Mooresville, NC 28117-7540

LOCATION / DIRECTIONS Brawley School Rd. TL Quaker Rd on left at corner

SUBDIVISION The Point BLOCK / SECTION 1C LOT # 32 LOT AREA 1.22 ac. DESIGN FLOW 480 gpd L.T.A.R. .25 gpd/ft²

(1850)

Septic Tank 1500 Gallons: STB 528 Date 12-10-07

Pump Tank 1500 Gallons: PT 485 Date 3-24-10

Pump Make Gaulds Model WE=05 12H Serial # E113703

Nitrification Field No Fields 1 No Lines 5★ Linear Feet 320

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type I II III (IV) V VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required ☒ YES ☐ NO

☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 4

☐ Business No. Persons 8

☐ Other No. Employees

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☒ Community

Comments / Conditions

★ 2 lines centerfed, 3 lines endfed

★ Okay to install swimming pool as shown on permit

10/18/11

Comments / Conditions 10/10/2011 Checked tanks. T2 Panels installed as shown Installed as shown 3/16" hole drilled

INITIAL SITE SKETCH

See plan from SAME

Approved by ICHD

AS BUILT SKETCH

11/7/2011 Set 3# pressure, checked float & alarm

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Chris Robillard Date 12-30-10 Installed by: Steve Gordons

Improvement Permit by: Judy Melville REHS Date 12-30-10 Operation Permit by: Judy Melville Date 11/7/2011

Authorization to Construct by: Judy Melville REHS Date 12-30-10 Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant