IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 148943 PIN # 4626-00-2110 DATE July 19, 2010

OWNER or APPLICANT Mid Atlantic/Stuart DeWitt PHONE: Business 704-202-1266 Ray Home: 704-746-6497 Brady

OWNER or APPLICANT ADDRESS PO Box 3792 Mooresville NC 28117

LOCATION / DIRECTIONS Brawley Sch. Rd. TR Chuckwood TL 1st Barber Loop on Right

SUBDIVISION Watertree Landing BLOCK / SECTION 4 LOT # 80 LOT AREA .69Ac DESIGN FLOW 480 gpd L.T.A.R. .3 gpd/ft²

Septic Tank 1000 Gallons: STB 1012 Date 4-6-09

Pump Tank 1000 Gallons: PT 1000 Date 1-19-09

Pump Make Goulds Model EPO4HA Serial #

Nitrification Field No Fields 1 No Lines 3 Linear Feet 400

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type I II (III) IV V VI

System Description: 25% reduction pm

Repair System Description: LP PPBPS

Maintenance Agreement Required ☐ YES ☒ NO

☐ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions

Comments / Conditions 7/21/2010 Checked tanks & lines. 7/23/2010 2ft pressure set.

INITIAL SITE SKETCH

See Plan from Michael Athanas & Associates Approved by ICHD

AS BUILT SKETCH

Installed as Drawn ADS 36

Location of the proposed Pergolla addition does not appear to impact the existing on-site septic system.**NOTE: Must be at least 5ft from Septic

Maria Dotson REHS

Date: 5/23/13

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: [signature] Date 7/20/10

Improvement Permit by: [signature] Date 7-19-10

Authorzation to Construct by: [signature] Date 7-19-10

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: Gunter's Grading

Operation Permit by: Maria Dotson REHS Date: 7/23/2010

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant