4626005844

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

R OR CONTRACTOR Ben Lee DATE 6-2-18 PERMIT NO. 107

ME: Business Home

ATION 400 ft E on 115 to L on 115C

BDIVISION NAME Hy Mt Estates LOT NO. 75 S. R. No.

House ( ) Mobile Home (X) Business ( ) Other SECTION OR BLOCK NO. 7

No. Bedrooms 3 No. Bathrooms 1 1/2

Garbage Disposal Unit Yes ( ) No (X)

Auto. Dishwasher Yes ( ) No (X)

Auto. Wash. Machine Yes (X) No ( )

Site Suitable Yes (X) No ( )

Lot Area 1 acre


Character & Porosity of Soil Clay loam

Percolation Rate 60 MPI

Topography Lot Slopes

Depth to Water Table 12"

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 12"

Water Supply: Individual (X)

Public ( )

Installed by Ray Lewis

OVEMENTS PERMIT BY

MENTS:

FICATE OF COMPLETION BY John Hunsucker DATE 6-20-18

ONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold