IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 375.00 Paid MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 119134 PIN# 4626-04-5249 DATE 5/18/04

OWNER OR CONTRACTOR ES Johnson Bldrs PHONE: Business 704-799-2876 Home

ADDRESS PO Box 1402 Cornelius NC 28031

LOCATION BSR, TR McKendree to the end, TL Kemp, on Lt

SUBDIVISION Pine Knoll Pt. BLOCK / SECTION LOT 17 LOT AREA 0.85 Ac SITE CLASS. PS DESIGN FLOW 360 L.T.A.R. 0.125 Lpp

Septic Tank: 1000 Gallons; STB 794 Date 9/21/04

Pump Tank: 1000 Gallons; PT 283 Date 9/21/04

Pump Make: Zoeller Model N 153 Serial No.

Nitrification Field: No Fields 1 Square Feet 2850 Linear Feet 576

No Lines 8 Trench Width 12" Max Trench Bottom Depth 16" Gravel Depth 8-10"

☒ New System ☐ Repair System Type: I, II, III, (IV), V, VI

System Description: LPP

Repair System Description: LPP

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Bathrooms 2½ No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Comments:/Conditions:

INITIAL SITE SKETCH

See LPP Plan By Tony Jacobs

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: RPM date 5-20-04 Installed by: Christeburg

Improvement Permit by: RS date 5/18/04 Operation Permit by: RS date 4/28/05

Authorization to Construct by: RS date 5/18/04 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK