IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR B. P. Griffin DATE 5-17-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1100 TR on 1115 at end TL. ¼ mi on right S. R. No. _____


SUBDIVISION NAME Lake Norman LOT NO. 190 SECTION OR BLOCK NO. 8

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area ¾ acre

Character & Porosity of Soil Sandy clay loam Porosity good
Percolation Rate not taken
Topography 20% Slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 650 Linear Ft. 262
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY _____

COMMENTS: System designed for above mobile Home and shower House.
* Tank is set 3' under ground

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 5-17-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold