DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Scott Whitten OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE: lot 27, Pine Trail / Pointe
WATER SUPPLY: On-Site Well ✓ Comm. Well Public Other EVAL. METHOD: Auger Boring ✓

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS	HORIZON LTAR
1	LS 10-15% ~28' from house	0-5"	SAB / CL	1:1 fr-fi					.3
		5-20	SAB / C	1:1 fi-vfi					
		20-41+	wk SAB / SC-SCL	1:1 fi					
2		0-19	wk SAB / CL	1:1 / sticky, sp					.3
		19-34	SAB / C	1:1 / fi					
		34-43+	wk SAB / SIC	1:1 / fi					
3									
4									
5									

AVAILABLE SPACE (.1945): PSA SITE CLASSIFICATION (.1948): PSX SITE LONG-TERM ACCEPTANCE RATE .3

EVALUATED BY: OTHER(S) PRESENT:

COMMENTS: PS per .1956 - modified systems, PPBPS — to be used for repair