IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Vernon Benson DATE 6-13-78 PERMIT NO. 117

PHONE: Business 324-2831 Home _____

LOCATION 400 ft on 115 Tl on 1446 T Ron rd

S. R. No. _____

SUBDIVISION NAME L H LOT NO. 186 SECTION OR BLOCK NO. 8

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Clay loam


Percolation Rate 60 min/in

Topography 2% Slope

Depth to Water Table 10'+

Rock or other impervious formations None

Lot Area 3/4 acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 1

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 12"+

Water Supply: Individual (✓)

Public ( )

Installed by Lear Thompson

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 6-13-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold