Taxes 9:45

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Wooten DATE Dec 12 '78 PERMIT NO.

PHONE: Business Home

LOCATION 1100 TR on 1115 TR on 2-2 1455 1st lot on left

S. R. No.


SUBDIVISION NAME L.N. LOT NO. 213 SECTION OR BLOCK NO. 8

House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	4-6 mpi	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	unk.	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	none obs.	
			Rock or other impervious formations		

Lot Area 1 Ac.



Plot of System

Size of Tank existing Gals.

Nitrification Field:
No. of Lines 1
Sq. Ft. 300 Linear Ft. 100
Depth of Stone in Lines 10" +

Water Supply: Individual (✓)
Public ( )

Installed by J. R. Bowles

IMPROVEMENTS PERMIT BY John Houston

COMMENTS:

CERTIFICATE OF COMPLETION BY David R. Henson DATE Dec 12 '78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold