IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James C. Wooten DATE 8-30-04 PERMIT NO. 234

PHONE: Business _____ Home 323-2540

LOCATION 1400 TR on 115 2 mi. TR on west 1st drive on left S. R. No. 1435

SUBDIVISION NAME Lake Norman LOT NO. 213 SECTION OR BLOCK NO. 5

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No ( )

Auto. Dishwasher Yes ( ) No ( )

Auto. Wash. Machine Yes ( ) No ( )

Site Suitable Yes ( ) No ( )

Lot Area 1 acre


Character & Porosity of Soil fine sandy clay loam (moderate fine)

Percolation Rate met table

Topography 30% slope

Depth to Water Table 48"

Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 675 Linear Ft. 225

Depth of Stone in Lines 12"

Water Supply: Individual ( )
Public ( )

Installed by John Poole

IMPROVEMENTS PERMIT BY J. C. Inspector

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Inspector DATE 8-30-04

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold