IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR M. L. Caldwell DATE 5-5-76 PERMIT NO. 139

PHONE: Business 876-3023 Home 873 5121

LOCATION 1100 Block Hill St Turn Right 1200 Block Lamar

S. R. No.

SUBDIVISION NAME Lake Norman LOT NO. SECTION OR BLOCK NO. 8

House ( ) Mobile Home (✓) Business ( ) Other

No. Bedrooms 2 No. Bathrooms 1½

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 1.20 Ac


Character & Porosity of Soil Clay loam

Percolation Rate 40 Min

Topography Rolling

Depth to Water Table 48"+

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 225 Linear Ft.

Depth of Stone in Lines

Water Supply: Individual (✓)

Public ( )

Installed by

IMPROVEMENTS PERMIT BY

COMMENTS:

CERTIFICATE OF COMPLETION BY DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold