IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5[illegible]

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

2130

PERMIT# 13242 / 1164439 PIN# ~~4626.07 4620.465~~ 4626070465 DATE Sept 19, 05

OWNER OR CONTRACTOR The Farms, LLC / Lake Norman Signature Homes PHONE: Business (704) 660-185 Home 704 202-3797

ADDRESS 2214 Brawley School Rd, Mooresville, N.C. 28117

LOCATION Brawley School Rd. TR McAndrew TR Spears Creek Dr. TL Cider Mill Place on right at end

SUBDIVISION The Farms BLOCK / SECTION 4 LOT 465 LOT AREA 1.248 ac SITE CLASS PS DESIGN FLOW 480 gpd L.T.A.R. e3

Septic Tank: ~~1000~~ + Shoot Gallons; STB 389 a Date 5-8-10

Pump Tank: 1500 Gallons; PT 390 Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1206 Linear Feet 402

No Lines 3@134' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: Gravity 25% Reduction

Repair System Description: Same

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms

☐ Business No. Employees

☐ Other

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments:/Conditions:

Original site evaluation and system design performed by Paul Pennuza and Kathleen Hines of S&ME

INITIAL SITE SKETCH

See Plan from S&ME

Comments:/Conditions: 2/17/2011 Drainlines installed essentially as Drawn. (No Dist. box used) Quick 4 Used ST on Side of House

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 9-29-05 Installed by: Gunter Grading RFH 2/18/11

Improvement Permit by: D.R. Johnson, REHS date 9-19-05 Operation Permit by: Maintenance Tech date

Authorization to Construct by: D.R. Johnson, REHS date 4-12-07 Existing System Inspection by: date

Judy Melville 12-3-10

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK