IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 13/238 PIN# 4626 07 1828.461 4626072658

OWNER OR CONTRACTOR The Farms LLC PHONE: Business (704) 660-1185 Home

ADDRESS 2214 Brawley Sch Rd, Mooresville, N.C. 28117 DATE Sept 20, 05

LOCATION Brawley Sch Rd. & R McKendree TR Spears Creek Drive 2nd lot on left

SUBDIVISION The Farms BLOCK / SECTION 4 LOT 461 LOT AREA .741 Ac SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .3

Septic Tank: ~~1000~~ 1500 Gallons; STB 3345 Date 5/19/06

Pump Tank: 1000 Gallons; PT 2383 Date 8/16/06

Pump Make: Gowlds Model WE03121-M Serial No.

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 4@100' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth

☒ New System ☐ Repair System Type: I, II, (III), IV, V, VI

System Description: PM 35% Reduction

Repair System Description: LPPBPS

Maintenance Agreement Required: ☐ Yes ☒ No initially

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Bathrooms No. Employees

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments/Conditions:

Original site evaluation and system design performed by Paul Pennington and Kathleen Hayes of S&ME

Comments/Conditions:

Pressure Reduction.
Drainlines & Tanks Checked 9/20/06 GM
Pressure head, elect & alarm Checked 1/24/07 JA

INITIAL SITE SKETCH

SEE Plan from S&ME

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed:

Improvement Permit by: date 9-29-05 Installed by: Abernethy

Authorization to Construct by: Judy Melvin date 9-20-05 Operation Permit by: John E Allyl date 6-9-06

Existing System Inspection by: date 1/24/07

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK