DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: The Farms, LLC APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 6/3/05
PROPOSED FACILITY: House PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: _____
LOCATION OF SITE: Lot 471 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	Linear 6-8%	0-4	mo GR SL	FR	DK Br				.3
		4-12	WK SBK SCL	SS SP FR	Br				
		12-28	MO SBK C	SS SP FR	Red; F inclusions Mica, gravelly				
		28-50	WK SBK CL	SS SP FR	Red; F inclusions Sap., F pale Br mottles yellow Br				
2	Linear 4-6%	0-4	Mo GR L	SS SP FR	DK Br				.25-.3
		4-8	WK SBK SCL	SS SP FR	Br				
		8-30	Mo SBK C	SS SP FR	Red; F weathered Rocks				
		30-48	WK SBK CL	SS SP FR	Red; C weathered Rock opp side less rock				.3+
3	9-9-05 9-10% V	0-5	wk sbk loam sch	fr (clay) SSSP					.25-.3
		5-28	mk SBK RC	fr SSSP SAP					
		28-48	WK SBK RCL	fr SSSP					
			+SAP + few mottle						
4		0-3	g wk sbk loam sch	fr SSSP					.25-.3
		3-36	mk SBK RC	fr SSSP SAP					
		36-52	WK SBK RCL	fr SSSP					
			+SAP						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____