IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTIO

PERMIT# 13/239 PIN# ~~4626-07-1828.462~~ 4626-07-3584 DATE Sept 20, 05

OWNER OR CONTRACTOR The Farms, LLC / Mecklenburg Homes PHONE: Business _____ Home _____

ADDRESS 2214 Brawley Sch Rd, Mooresville, NC 28117

LOCATION Brawley Sch Rd TR McKendree TR Speas Creek Dr. TR Cider Mill Pl. on left in cul-de-sac

SUBDIVISION The Farms BLOCK / SECTION 4 LOT 462 LOT AREA ±.767 Ac. SITE CLASS. PS DESIGN FLOW 480 gpd L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 444 Date 3-16-06

Pump Tank: 1000 Gallons; PT 27 Date 2-23-06

Pump Make: Gould's Model WE0312M4 Serial No. _____

Nitrification Field: No Fields 1 Square Feet 540/810 Linear Feet 270

No Lines 3@90 Trench Width 24"min 48"oc Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: LPPPBPS

Repair System Description: LPPPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms ____

☐ Business No. Employees ____

☐ Other _____

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments/Conditions: ~~OF~~ 36" MAX 90c

Initial site evaluation and system design performed by Paul Pennington and Kathleen Haven of S&ME

INITIAL SITE SKETCH

SEE PLAN from S&ME

Comments/Conditions: Reviewed Building plans; essentially in compliance with Improvement Permit except House is 65 Ft depth instead of 60 Ft

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 9-28-05 Installed by: Abernathy

Improvement Permit by: _____ date 9-20-05 Operation Permit by: _____ date 9/12/06

Authorization to Construct by: _____ date 11/11/06 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK