IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

375

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 13/236 PIN# 4626 07 1828.460 4626-07-3761 DATE Sept 20, 05

OWNER OR CONTRACTOR The Farms LLC / Craig Carter PHONE: Business _____ Home _____

ADDRESS 2214 Brawley School Rd, Mooresville, N.C. 28117

LOCATION Brawley School Rd TR McKendree on Right at jct with Speans Creek Dr.

SUBDIVISION The Farms BLOCK / SECTION 4 LOT 460 LOT AREA .75 Ac SITE CLASS. PS DESIGN FLOW 480 gpd L.T.A.R. .03

Septic Tank: ~~1000~~ 1500 Gallons; STB 338 Date _____

Pump Tank: 1000 Gallons; PT 293 Date _____

Pump Make: Myers Model ME50 Serial No. _____

Nitrification Field: No Fields 1 Square Feet 534/801 Linear Feet 267

No Lines 2 (CF) Trench Width 24" min Bloc Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: LPPPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms _____

☐ Business No. Employees _____

☐ Other _____

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments/Conditions: OR = 36" max bloc

Elevation of site evaluation and system design performed by Paul Pennington and Kathleen Haven of S&ME

Comments/Conditions: 2/8/06 Reviewed Building plans; essentially in Compliance with I.P.

INITIAL SITE SKETCH

SEE PLAN from S&ME

AS BUILT SKETCH

Permit can be ~~suspended~~ or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 9-29-05 Installed by: Paul Howard

Improvement Permit by: _____ date 9-20-05 Operation Permit by: _____ RS date 6/21/06

Authorization to Construct by: _____ RS date 2/8/06 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK