# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ronnie Darnell DATE 9-15-16 PERMIT NO. 267

PHONE: Business _____ Home 546-4106

LOCATION: 100 Top 115 To Lake Norman

Site 1P 3rd Lot on Left S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 174 SECTION OR BLOCK NO. 8

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes ( ) No (✓)

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 1 Acre


Character & Porosity of Soil Clay Loam Poorly Fair

Percolation Rate Mod Fast to Fast

Topography 3% Slope

Depth to Water Table 10'

Rock or other impervious formations None




Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 5

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 24"

Water Supply: Individual (✓)

Public ( )

Installed by Lawrence Service

IMPROVEMENTS PERMIT BY J C Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 9-22-16

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold