DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: The Farms, LLC APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 6/3/05
PROPOSED FACILITY: House PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: _____
LOCATION OF SITE: Lot 475 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L ~10%	0-19	CL - SBK/ABK	fr 0/-	RED		P5		P5 -36
		19-37	scl - w SBK	fr 35/sc					
		37-56	sl-0 m	fr 15/sl					
			SAP						
2	L ~15%	0-4	sil gr	fr 55/sl	br red mott red-yell	Very wary Bedrock	4+		P W
		4-22	C SBK/ABK	fr 0/-					
		22-48	cl-sd w SBK	fr 55/sp					
		48-60	sl-l m	fr 55/sc					
3	L ~15%	0-3	sil sc	fr 55/sc	br r mott red yell		P5		P W
		3-25	C w SBK	fr 0/-					
		25-43	cl-sd w SBK	fr 55/sp					
		43-55	l-sl m	fr 35/-					
A	L ~15% New 9-16-05	0-36	SBK CL	SS SP FR	Red; Yel Red	SAP			.3
		36-62	WK SBK/MA L SAP	SS SP FR					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____