DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Darrell Hoke APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: ___
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: ___
LOCATION OF SITE: Lake Wheeler Shores PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	7-10%	0-19	RBrscl wsbk	Fr sss p	—	48"	—	—	PS 0.3
		19-48	Rc/cl sbk	Fr ss sp					
2	7-10%	0-10	Fill		—	60"	—	—	PS 0.3
		10-20	Brscl wsbk	Fr sss p					
		20-48	Rc sbk	Fr ss sp					
		48-60	Rcl wsbk	Fr ss sp					
3	10%	0-21	Fill (Fill starts @ 21" at one End and goes to 7" on the other end)		—	74"	F-c Inc 390	—	PS 0.3
		21-24	Brscl wsbk	Fr sss p					
		24-52	Rc sbk	Fr sss p					
		52-74	Rcl wsbk	Fr sss p					
4	7-10%	0-33	Fill		— Must Remove Fill	30"	—	—	PS 0.3
		33-64	Rc sbk	Fr ss sp					
		64-80	Rcl wsbk	Fr ss sp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	670 Ft²	670 Ft²
System Type(s)	PPBDS	PPBDS
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: MA & Assoc.
OTHER(S) PRESENT: ___