4626094280

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Donald P. Smith DATE 1-4-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1100 T R on 1115 T Rom 1455 , 1st left Bare Lilac at Fork S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 250 SECTION OR BLOCK NO. 8


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2 1/2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 3/4 ac

Character & Porosity of Soil Existing System
Percolation Rate _____
Topography _____
Depth to Water Table _____
Rock or other impervious formations _____



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250'
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by E.J. Ervin
Installed 5-15-77

IMPROVEMENTS PERMIT BY _____

COMMENTS: System Working OK at Time of this Inspection

CERTIFICATE OF COMPLETION BY John Houston DATE 1-4-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold