IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert Hippen DATE 3-7-84 PERMIT NO. 40

PHONE: Business 521-4303 Home 521-7531

LOCATION 1100 IR 1115 IR 1455 Block IR 1292 (Abbot Road) BEAR left ON 1455 IR dirt street on left in woods SR. No.

SUBDIVISION NAME Lake Norman LOT NO. 255 SECTION OR BLOCK NO. 8

House (X) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (X)

Auto. Dishwasher Yes (X) No ( )

Auto. Washing Machine Yes (X) No ( )

Site Suitable Yes (X) No ( )

Lot Area 2 3/4 mile

Character & Porosity of Soil Clay Loam


Percolation Rate 0.5 gpf 1 day 16-60 1 gpf

Topography

Depth to Water Table

Rock or other impervious formations None observed

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 720 Linear Ft. 240

Depth of Stone in Lines 12"

Water Supply: Individual (X) Public ( )

Installed by

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Robert Hippen

IMPROVEMENTS PERMIT BY Fred Clemmer

COMMENTS: Keep System shallow follow contours; divert surface H2O away from N.I. fields Lines (Relayout of Jerry Rogers permit Attached)

CERTIFICATE OF COMPLETION BY

EXISTING SYSTEM CHECKED BY: DATE

DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold