# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ted Lowery DATE 5-12-77 PERMIT NO. 111

PHONE: Business _____ Home _____

LOCATION 100' SR on NS 70 on W5 of Lily Sta. 1st Dirt to right at end S. R. No. _____

SUBDIVISION NAME Lakeshore LOT NO. 259 SECTION OR BLOCK NO. 5


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Sandy Clay loam Fair
Percolation Rate Soil Limits
Topography Fair Slope
Depth to Water Table 6 to 10'
Rock or other impervious formations None

Lot Area 1 acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Sam Stuart

IMPROVEMENTS PERMIT BY John Hawkins

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Hawkins DATE 5-12-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold