IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Glenn R. Morgan DATE 10-5-95 PERMIT NO. 298

PHONE: Business _____ Home 536-5342

LOCATION 1100 ft on 1115 to TR on ; 1175 ft on left 2nd right after crossing S. R. No. 1115


SUBDIVISION NAME Lake Norman LOT NO. 260 SECTION OR BLOCK NO. 2

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Clay loam Porosity Fair
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Soil Tested
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Rolling Stone
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10' +
			Rock or other impervious formations	None

Lot Area Acre



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 225 Linear Ft. 250
Depth of Stone in Lines 18"

Water Supply: Individual (✓)
Public ( )

Installed by E. T. Sprinkle

IMPROVEMENTS PERMIT BY L. Conner

COMMENTS: Changed Tank To 1250 gal (L.Conner) 10-10-95

CERTIFICATE OF COMPLETION BY L. L. Conner DATE 10-5-95

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold