4626112507

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William E Helms DATE 5-30-78 PERMIT NO. _____

PHONE: Business 883-1196 Home 528-3101

LOCATION 1109 TR on 1107 at end

S. R. No. 1107


SUBDIVISION NAME Lake Norman LOT NO. 7 SECTION OR BLOCK NO. 6

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Sandy Clay & Rock
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	45 min/inch
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Hilly Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10' at end of lines
			Rock or other impervious formations	Rock

Lot Area 3 Acres



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by E J Irwin

IMPROVEMENTS PERMIT BY D. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY D. C. Moore DATE 5-30-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold