4626112507.

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William E. Helms DATE 5-30-78 PERMIT NO. _____

PHONE: Business 283-1196 Home 528-3101

LOCATION 1100 TRON 1177 at end

S. R. No. 1170

SUBDIVISION NAME Lake Norman LOT NO. 7 SECTION OR BLOCK NO. 61


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 3/4 acre

Character & Porosity of Soil Sandy Clay + rock
Percolation Rate 45 min/inch
Topography 4% Slope
Depth to Water Table 10'+
Rock or other impervious formations [redacted] rock
Present at end of lines



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by E J Irvin

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 5-30-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold