1,130

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William C Helms DATE 4-14-08 PERMIT NO. _____

PHONE: Business 393-1196 Home 537-3101

LOCATION Hwy 115 TR on 1122 at end

S. R. No. 1122

SUBDIVISION NAME Lake Norman LOT NO. 7 SECTION OR BLOCK NO. 4

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit	Yes	( )	No	(/)
Auto. Dishwasher	Yes	( )	No	(/)
Auto. Wash. Machine	Yes	(/)	No	( )
Site Suitable	Yes	(/)	No	( )

Lot Area Marked


Character & Porosity of Soil Sandy clay & decomposed rock

Percolation Rate 45 min/inch

Topography 15% Slope

Depth to Water Table 16'

Rock or other impervious formations Some rock & possibly some ledge rock above surrounding area



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 600 Linear Ft. 200

Depth of Stone in Lines 24"

Water Supply: Individual ( )
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY J.C. Moore

COMMENTS: Install bottom no more than 24" deep. Each 50' length of trench to be 2' apart. Earth not to be used over rock. Must have rock above pipe.

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold