2:30

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 150831 PIN # 4626-11-4019 DATE April 5, 2011

OWNER or APPLICANT Cottonwood Homes PHONE: Business 704-400-7202 Home:

OWNER or APPLICANT ADDRESS P.O. Box 2022 Cornelius NC 28031

LOCATION / DIRECTIONS Brawley School Rd. TR Chuckwood TL 2nd Barber Loop on Left

SUBDIVISION Watertree Landing BLOCK / SECTION 5 LOT # 84 LOT AREA .77Ac. DESIGN FLOW 480gpd. L.T.A.R. .3 gpd/ft²

Septic Tank 1000 Gallons: STB 794 Date 1-8-11

Pump Tank ____ Gallons: P T ____ Date ____

Pump Make ____ Model ____ Serial # ____

Nitrification Field No Fields 1 No Lines 4 Linear Feet 400

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth NA ☒ GRAVITY ☐ PRESSURE

☒ New System ☐ Repair ☐ Expansion System Type I II III IV V VI

System Description: 25% Reduction Gravity

Repair System Description: LPPPBPS

Maintenance Agreement Required ☐ YES ☒ NO

☒ Residence No. Bedrooms 4 ☐ Business No. Persons ____ ☐ Other No. Employees ____

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions

Follow state rules

Keep drainfield lines 10' from PL

Comments / Conditions 9/1/2011 Checked ST & top 2 lines. Bottom lines Checked 9/13/11

ADS 36

INITIAL SITE SKETCH

See Plan from Michael Athanas & Associates Approved by ICHD

AS BUILT SKETCH

Installed 4 - 100 lines

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration.* ☒ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Blue McDaniel Date 4-7-11

Improvement Permit by: Judy Melville REHS Date 4-5-11

Authorzation to Construct by: Judy Melville REHS Date 4-7-11

Installed by: R&T Construction PS

Operation Permit by: Michael Watson Date: 9/13/11

Existing System Inspected by: ____ Date: ____

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant