DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ *of* ____
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____
ADDRESS: _____ APPLICATION DATE _____
PROPOSED FACILITY: _4 bedroom_____ PROPOSED DESIGN FLOW (.1949): __480 GPD____ DATE EVALUATED: _____
LOCATION OF SITE: _Watertree Landing Lot 88_____ PROPERTY SIZE: _____
WATER SUPPLY: ☒ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
1	LS 5%	30+"	FILL						US
2	LS 5%	0-20	FILL			48"			PS 0.3
		20-48	R C SBK	FR SS SP					
3	LS 5%	0-10	FILL		Few YBs	48"			PS 0.25
		10-48	R C SBK	FR SS SP					
4	LS 5%	0-20	NO FILL						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1440 FT2	640 FT2
System Type(s)	25% Reduction	PPBPS
Site LTAR	0.25 (ICHD)	0.25 (ICHD)

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _M A & Assoc._____
OTHER(S) PRESENT: _____

COMMENTS: _____