4626125584

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenneth Meadows DATE 8-1-78 PERMIT NO. 186

PHONE: Business _____ Home 919-765-7299

LOCATION 1100 TR on 1177 TR on 1238 1st Rd to _____ S. R. No. _____


SUBDIVISION NAME L. D. LOT NO. 49 SECTION OR BLOCK NO. 7

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	60 min/in	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	5% slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	6' to 8'	
			Rock or other impervious formations	Look at ends of lines	

Lot Area ¾ acre



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by J. R. Bowles

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 8-1-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold