10:00

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Hall DATE 8-7-98 PERMIT NO. 224

PHONE: Business _____ Home _____

LOCATION 177 TL on 1238 2 mi on Left

_____ S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 47 SECTION OR BLOCK NO. 7

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes	(✓)	No	( )	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Character & Porosity of Soil Sandy Clay


Percolation Rate 30 min/inch

Topography 2 to 6% slope

Depth to Water Table 10 ft

Rock or other impervious formations Some Surface Rock

Lot Area 3 3/4 Acre



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: Change Layout Dated 11-11-97

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold