DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Jane Klein OWNER: AGENT: PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: ____
PROPOSED FACILITY: ____
PROPERTY SIZE: .83 Ac.
LOCATION OF SITE: Section 8, lot 138
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ____ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___
Existing

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	Ridge/ 5S	0-13"	SAB / CL	1:1 / s/s/slpl			PS	-	.4
		13-40+	SAB / C	1:1 / vfi	relic mottles 23"+		PS	-	.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945): Ok SITE CLASSIFICATION (.1948): PS per o 1956 SITE LONG-TERM ACCEPTANCE RATE: .03
EVALUATED BY: DRFinson OTHER(S) PRESENT: ____
COMMENTS: Lot recorded prior to 1983. Repair area not required but some will be available with use of PPBPS.