4626171567

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William M. Davis Jr. DATE 6-21-79 PERMIT NO. 216

PHONE: Business _____ Home _____

LOCATION 1100 ft on 1115 ft on 1446 . 1 mi on Rt.

S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. 166 SECTION OR BLOCK NO. 8


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes ( ) No (✓)
Site Suitable Yes (✓) No ( )

Lot Area 1.2 AC.

Character & Porosity of Soil clay loam
Percolation Rate Rapid
Topography Rolling
Depth to Water Table 6'+
Rock or other impervious formations none obs.



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"+
Water Supply: Individual (✓)
Public ( )

Installed by F J Ervin

IMPROVEMENTS PERMIT BY David R. Henson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Henson DATE 6-21-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold