IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-528

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 13/325 PIN# 4626 09 1028.502 4626-18-2508

OWNER OR CONTRACTOR The Farms, LLC / Craig Carter PHONE: Business (704) 660-1185 Home DATE Sept 21, 05

ADDRESS 2214 Brawley Sch Rd Mooresville, N.C. 28117

LOCATION Brawley Sch Rd. / TR McKendree TR Barefoot Cove 1st lot on Right

SUBDIVISION The Farms BLOCK / SECTION 4 LOT 302 LOT AREA .249 Ac SITE CLASS. PS DESIGN FLOW 440 gpd L.T.A.R. .3

Septic Tank: 1500 Gallons; STB 530 Date 4/10/06

Pump Tank: 1000 Gallons; PT 32 Date 4/10/06

Pump Make: Myers Model ME33S-21 Serial No.

Nitrification Fields No Fields 1 Square Feet 540/610 Linear Feet 270

No Lines 3 (CF) Trench Width 24" min 36" Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair System Type: I, II, III, (IV), V, VI

System Description: LP PPBPS

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Bathrooms

☐ Business No. Employees

☐ Other

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: ☐ Individual ☒ Public ☒ Community

Comments:/Conditions: OR = 36" max 96c

Initial site evaluation and system design performed by Paul Fearrington and Kathleen Howard of S&ME

Comments:/Conditions: 2/8/06 Reviewed Building plans essentially in Compliance with I.P

INITIAL SITE SKETCH

116
87
58
293

SEE PLAN from S&ME

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed:

Improvement Permit by: date 9-21-05

Authorization to Construct by: RS date 2/8/06

Installed by: Howard Engineering

Operation Permit by: RS date 11/3/06

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK